

御注文主
CUSTOMER数 量
QUANTITY台
SET

MATERIALS LIST

No.	Denomination	Material
1	Cable(power/control)	STOW(105°C) UL62 Polyvinylchloride sheathed cable
2	Cable entry	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
4	Handle	S C S 1 3 / S U S 3 0 4 (ASTM S30400) Stainless Steel Casting / Stainless Steel
6	Stator	_____
7	Rotor Assembly	Shaft=S U S 4 2 0 J 2 Stainless Steel
10	Stator Casing	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
11	Upper Bearing	_____
12	Lower Bearing	_____
13	Bearing Cover	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
14	Oil Casing	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
15	Impeller	F C 2 5 0 (ASTM A48 Class 35) / S C S 1 3 Gray Iron Casting / Stainless Steel Casting
17	Pump Casing	F C 2 5 0 (ASTM A48 Class 35) Gray Iron Casting
18	Mechanical Seal	Upper : SiC/SiC Lower : SiC/SiC
21	Stand	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
23	Oil	Turbine Oil #32
24	Air Valve	Locating Pin : P.E Ball : N.B.R
26	Wear ring	Brass casting
28	Mechanical Seal Bracket	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting
109	O Ring	NBR Nitrile butadiene rubber
110	Oil Plug	S U S 3 0 4 (AISI 304) Stainless Steel
115	Leakage Detector	_____
117	Cable Clamp	S U S 3 0 4 (AISI 304) Stainless Steel
118	Plug for Motor Room	S U S 3 0 4 (AISI 304) Stainless Steel
119	Leakage Detector Cover	F C 2 0 0 (ASTM A48 Class 30) Gray Iron Casting

 1805001	製 図 DWG.	H. Kakimoto	Dec-27-2010	名称 TITLE 材 質 表 (MATERIALS LIST)	図 番 DWG No. AY0763	Δ 2
	検 図 JUDG.	K. Takeuchi	Dec-27-2010			
	承 認 APPD.	A. Ando	Dec-27-2010			